



TESTA ENGINEERING  
ASSOCIATES  
Structural Engineering

181 Worcester Street  
Natick, MA 01760  
Tel: (508) 655-2420

Invoice: 2023 – 0166  
Date: 5/22/2023

Stack Plumbing Heating & Gas  
275 Pleasant Street  
Watertown, MA 02472  
ATTN: Adam Stack

Project: 2 – 6 Powder Mill Road  
Maynard, MA

Dear Adam,

I have inspected the existing retaining wall at 2 – 6 Powder Mill Road in Maynard.

The existing retaining wall is in excellent condition however it does not meet the current Massachusetts State Building Code. It will need to be reinforced to meet the current code.


The wall can be reinforced from the non-Water side of the existing wall by increasing the thickness of the wall and attaching this to the existing wall.

All of this work can be done without doing any work on the water side of the existing retaining wall.

If you have any questions, please feel free to call me at 508-655-2420.

Sincerely yours

Richard J. Testa Jr. P.E.  
License #: 37868



5/22/2023