

4/28/13

Maynard Conservation Commission  
Maynard Town Hall  
195 Main Street  
Maynard, MA 01754

Re: Weekly Erosion Control Report (Week 2)  
129 Parker Street, Maynard, MA

Dear Maynard Conservation Commission:

Goddard Consulting, LLC is pleased to submit this site inspection and erosion control report on behalf of Capital Group Properties in accordance with the approved SWPPP (EPA Tracking MAR12AI87) and the Maynard Stormwater Bylaw Permit.

**SITE VISITS:** Goddard has visited and inspected the site on 4/23 and 4/27 in the course of routine site inspections and will continue on an ongoing basis. There were no notable storms during this period, and no significant erosion has been noted in the downgradient receiving stream. The measures outlined in the approved SWPPP are in the process of being implemented.

**GENERAL SITE ACTIVITIES:** Some on-site crushing and sorting continues. This is scheduled for continue for several more weeks.

**EROSION SPECIFIC ACTIVITIES:** The following activities were performed:

- Routine street sweeping.
- Hosing for dust control during crushing.
- On site meeting with site supervisor to implement SWPPP.

**IMMEDIATE ACTION ITEMS NEEDED:**

- All catch basins to be protected with double filter fabric on top and bottom. The edge will be sprayed with orange color surveying paint to alert traffic from tearing up fabric.
- Install protected sediment riser at three low depression areas to form sediment basin to settle sediment and construction dust washed from the parking lot traffic. See Plan for locations.
- Install woodchip check dam around the exposed soil under the demolished building to preserve the sand; if needed a second line of silt fence can be added around the woodchips to prevent washout.
- Created depression inside the building envelope and make a spill way toward near by Sediment basin riser. The spill way shall be lined with geotextile and 2" crushed stones.
- 6" thick 2" stone mud trap shall be installed between paved area and the disturb soil area for traffic.

- Parking lot shall be inspected and swept weekly and/or before rain storm events during active demolition and quarterly or as needed post demolition given no traffic is expected at the property.

**LONG-TERM ACTION ITEMS NEEDED:**

- Sediment deposit shall be removed from the sediment basin if the deposit exceeds 6" and when demolition is completed.

If there are any questions concerning this submission, please do not hesitate to contact us.

Sincerely,  
Goddard Consulting, LLC

by



Scott G Goddard, PWS  
Professional Wetland Scientist

Distribution List via email:

- William Depietri, Capital Group Properties, LLC ([wdepietri@me.com](mailto:wdepietri@me.com))
- Todd Lyons, JBJ Construction ([tlyons@bjcc.net](mailto:tlyons@bjcc.net))