

7/2/13

Maynard Conservation Commission  
Maynard Town Hall  
195 Main Street  
Maynard, MA 01754

Re: Weekly Erosion Control Report (Weeks 9-12)  
129 Parker Street, Maynard, MA

Dear Maynard Conservation Commission:

Goddard Consulting, LLC is pleased to submit this site inspection and erosion control report on behalf of Capital Group Properties in accordance with the approved SWPPP (EPA Tracking MAR12AI87) and the Maynard Stormwater Bylaw Permit.

**SITE VISITS:** Goddard has visited and inspected the site on 6/11/13, 6/13/13, 6/14/13, 6/19/13, 6/27/13, and 7/1/13 in the course of routine site inspections and/or after measurable storm events. There has been a weather pattern of regular light to heavy rain events for the past several weeks. During these recent rain events no erosion occurred in the downgradient receiving stream. Goddard noted that two catch basins along the southern edge of Building 100 are still unprotected. The other measures outlined in the approved SWPPP have been implemented including the riser pipes at select catch basins.

**GENERAL SITE ACTIVITIES:** A final post-demolition sweep has been completed.

**EROSION SPECIFIC ACTIVITIES:** The following activities were performed:

- Routine street sweeping.
- Implemented SWPPP measures of riser pipes.

**IMMEDIATE ACTION ITEMS NEEDED:**

- All catch basins to be protected. Some are still unprotected. The edge shall be sprayed with orange color surveying paint to alert traffic from tearing up fabric.
- Parking lot shall be inspected and swept quarterly or as needed post demolition given no traffic is expected at the property.


**LONG-TERM ACTION ITEMS NEEDED:**

- Sediment deposit shall be removed from the sediment basin if the deposit exceeds 6”.

If there are any questions concerning this submission, please do not hesitate to contact us.

Sincerely,  
Goddard Consulting, LLC

by



Scott G Goddard, PWS  
Professional Wetland Scientist

Distribution List via email:

- William Depietri, Capital Group Properties, LLC ([wdepietri@me.com](mailto:wdepietri@me.com))
- Todd Lyons, JBJ Construction ([tlyons@bjcc.net](mailto:tlyons@bjcc.net))